

VERIFICATION OF COMPLIANCE

No.: UKCA LVD SHES2201000974AT

Applicant: Zhejiang CHINT Instrument & meter Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang, China.

Manufacturer: Zhejiang CHINT Instrument & meter Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang, China.

Product Name: Smart Power Sensor

Product Description: Smart Power Sensor

Model No.: DTSU666-HW

Trade Mark: CHINT

Rating: 230/400V, 3~; 50/60Hz, 1,5W max, 6VA max; Channel 1:
5(80)A, Class 1, 400imp/kWh; Channel 2: 1,5(6)A, Class 0.5S,
6400imp/kWh

Protection against Electric Shock: Class II

Additional Information: None

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 61010-1:2010 + A1:2019;
EN IEC 61010-2-030:2021

as shown in the

Test Report Number(s): SHES220100097401

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant designated standards under UK Legislation - Electrical Equipment (Safety) Regulations 2016. The UKCA marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of a UK Declaration of Conformity and compliance with all relevant UK Legislations.

Andrew Zhai
Technical Manager
SGS-CSTC



2022-02-28

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services which can be accessible at <https://www.sgs.com/en/terms-and-conditions>.

Member of SGS Group (Société Générale de Surveillance)