

## CERTIFICATE

No. Z2 099333 0053 Rev. 02

**Holder of Certificate:** 

LONGi Green Energy Technology Co., Ltd.


No. 388, Middle Hangtian Road

Chang'an District

710100 Xi'an City, Shaanxi

PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:** 



**Product:** 

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no .:

704061700519-02

Valid until:

2024-07-17

Date,

2019-07-26

(Zhulin Zhang)

potis



## CERTIFICATE

No. Z2 099333 0053 Rev. 02

Model(s):

LR6-72HV-xxxM (xxx=335-360, in step of 5) LR6-60HV-xxxM (xxx=280-300, in step of 5) LR6-72PH-xxxM (xxx=340-380, in step of 5) LR6-60PH-xxxM (xxx=285-315, in step of 5) LR6-72HPH-xxxM (xxx=365-395, in step of 5) LR6-60HPH-xxxM (xxx=300-325, in step of 5) LR6-72OPH-xxxM (xxx=385-400, in step of 5) LR6-60OPH-xxxM (xxx=335-350, in step of 5) LR6-72HPH-xxxMC (xxx=375-390, in step of 5) LR6-60HPH-xxxMC (xxx=305-325, in step of 5) LR4-72HPH-xxxM (xxx=420-440, in step of 5) LR4-60HPH-xxxM (xxx=350-370, in step of 5) xxx is standing for rated output power at STC.

Parameters:

Fire Safety Class:

Class C according to UL790. Class A

Application Class: Max. System Voltage:

1500V DC Test method a of IEC TS 62804-1:2015

PID Test Condition:

±1500V DC, 96 hrs, 85 % RH, 85 °C.

Framed, with Junction box, cable and connector.

**Tested** according to:

IEC 61215(ed.2)

Construction:

IEC 61730-1(ed.1);am1;am2 IEC 61730-2(ed.1);am1 PPP 58042B:2015

Production Facility(ies):

099626, 099606, 090968, 001192, 096558, 099605, 002875, 097323, 102892, 103410, 103841